

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7770-0531:110

Page 1 of 1

CATEGORY: Valves/Switches

LISTEE: Victaulic Company of America, PO Box 31, Easton PA 18042-0031
Contact: *Mike John (610) 559-3468

DESIGN: Model *FireLock 758* deluge type, deluge type with preaction trim alarm check valves. All units are for vertical and horizontal installation position. Sizes ranging from 1-1/2", 2", 2-1/2" and 3" for Groove/Groove end configuration and 4", 6" for groove/Groove, Flange/groove end configuration. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 300 psig

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number and UL label.

APPROVAL: Listed as deluge type, deluge type with preaction trim alarm check valve for use with fire sprinkler systems.

*Rev. 08-20-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

AUGUST 20, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager